

## Coast Guard, DOT

## § 76.05-1

### Subpart 76.35—Manual Alarm System, Details

- 76.35-1 Application.
- 76.35-5 Zoning.
- 76.35-10 Location and spacing of manual alarm boxes.
- 76.35-15 Operation and installation.
- 76.35-90 Installations contracted for prior to November 19, 1952.

### Subpart 76.50—Hand Portable Fire Extinguishers and Semiportable Fire Extinguishing Systems, Arrangements and Details

- 76.50-1 Application.
- 76.50-5 Classification.
- 76.50-10 Location.
- 76.50-15 Spare charges.
- 76.50-20 Semiportable fire extinguishers.
- 76.50-90 Vessels contracted for prior to November 19, 1952.

### Subpart 76.60—Fire Axes

- 76.60-1 Application.
- 76.60-5 Number required.
- 76.60-10 Location.

AUTHORITY: 46 U.S.C. 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; 49 CFR 1.46.

SOURCE: CGFR 65-50, 30 FR 16940, Dec. 30, 1965, unless otherwise noted.

### Subpart 76.01—Application

#### § 76.01-1 General.

- (a) The provisions of this part shall apply to all vessels except as specifically noted in this part.
- (b) [Reserved]

#### § 76.01-2 Incorporation by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register in accordance with 5 U.S.C. 552(a). To enforce any edition other than that specified in paragraph (b) of this section, the Coast Guard must publish notice of change in the FEDERAL REGISTER and make the material available to the public. All approved material is on file at the Office of the

Federal Register, 800 North Capitol Street NW, suite 700, Washington, DC, and at the U.S. Coast Guard, Office of Design and Engineering Standards (G-MSE), 2100 Second Street SW., Washington, DC 20593-0001 and is available from the sources indicated in paragraph (b) of this section.

(b) The material approved for incorporation by reference in this part and the sections affected are:

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)  
100 Barr Harbor Drive, West Conshohocken, PA 19428-2959

ASTM F-1121, International Shore Connections for Marine Fire Applications, 1987: 76.10-10

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

1 Batterymarch Park, Quincy, MA 02269-9101

NFPA 13-1996, Standard for the Installation of Sprinkler Systems—76.25-1

[CGD 88-032, 56 FR 35824, July 29, 1991; 57 FR 31947, July 20, 1992, as amended by CGD 95-072, 60 FR 50463, Sept. 29, 1995; CGD 96-041, 61 FR 50729, Sept. 27, 1996; CGD 97-057, 62 FR 51045, 51204, Sept. 30, 1997]

#### § 76.01-5 Equipment installed but not required.

- (a) Where fire detecting or extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation shall meet the requirements of this part.
- (b) [Reserved]

### Subpart 76.05—Fire Detecting and Extinguishing Equipment, Where Required

#### § 76.05-1 Fire detecting systems.

(a) Approved fire detecting systems shall be installed in locations as required by table 76.05-1(a) on the following vessels:

- (1) Any vessel on an international voyage.
- (2) Any vessel of more than 150 feet in length having sleeping accommodations for passengers.

TABLE 76.05-1(A)

Space	Detecting systems	Fixed extinguishing systems
<i>Safety areas</i>		
Wheelhouse or fire-control room .....	None required <sup>1</sup> .....	None required <sup>1</sup>
Stairway and elevator enclosures .....	do <sup>1</sup> .....	Do. <sup>1</sup>